

**Bear Creek Clean Water Initiative
Follow-up Investigations on Priority Drains**

Drain Name: Bear Creek Warren Branch South Drain ID#: 708-1

*Initial Sample Results: 2,247 cfu/100ml Occurrence: Dry Weather / ~~Wet Weather~~

Date MCPWO Initially Notified of Sample Result: 9/25/00

Date	Action Taken
9/27/00	The City of Warren identified an illicit connection from parts of an industrial facility on Rinke St.
10/17/00	The Rinke St. connection was corrected by a private contractor hired by the property owner.
7/15/01	City of Warren eliminated an illicit connection from an industrial facility located on Nine Mile Rd.

*Follow up not required under the work plan, however illicit connections were found as part of the City of Warren's Illicit Connection Elimination Program.