

**Bear Creek Clean Water Initiative
Follow-up Investigations on Priority Drains**

Drain Name: Kutchey-Warren Branch Drain ID#: 709-1

Initial Sample Results: 22,256 cfu/100ml Occurrence: ~~Dry Weather~~ / Wet Weather

Date MCPWO Initially Notified of Sample Result: 6/21/01

Date	Action Taken
6/22/01	Requested sanitary sewer plans from the City of Warren
8/9/01	Reviewed drain plans.
8/10/01	Located manhole for follow-up sampling.
8/21/01	Authorized installation of sampler at upstream site. Sampler installed.
9/8/01	Results were elevated (geometric mean = 3,822 cfu/100ml)
9/17/01	Sent the City 'Order for Corrective Action'
10/7/02	Installed autosampler in an upstream manhole (709-14) by the Macomb/Oakland County border.
10/13/02	Autosampler collected 2 samples from a rain event the prior night. The results were elevated but not as high as at the outlet (2,187 and 6,131 cfu/100 ml).