

**Bear Creek Clean Water Initiative
Follow-up Investigations on Priority Drains**

Drain Name: Bear Creek Warren Branch No.2 Drain ID#: 723-21

Initial Sample Results: 22,144 cfu/100mL Occurrence: ~~Dry Weather~~ / Wet Weather

Date MCPWO Initially Notified of Sample Result: 9/13/01

Date	Action Taken
10/24/01	Reviewed storm drain plans
10/14/02	City of Warren eliminated a commercial sanitary lead to the drain located on Ten Mile near Mound Rd.
10/17/02	Installed autosampler in an upstream manhole (723-5).
11/11/02	Sampler collected 8 samples from previous night's rainfall (1.37"). The geometric mean of the five samples submitted was low (936 MPN/100 ml).